



All vehicles must have an approved Fire Marshal permit in order to be on the trade show floor. Please submit the form below by Monday, September 7, 2022, you will have a vehicle on the show floor.

**ONSITE RULES FOR VEHICLES**

Fuel tank openings shall be locked or sealed in an approved manner to prevent escape of vapors; fuel tanks shall not contain more than one -quarter their capacity or contain in excess of 19L (five gal.) of fuel, whichever is less. At least one battery cable shall be removed from the batteries used to start the vehicle engine, and the disconnected battery cable shall then be taped. Batteries used to power auxiliary equipment shall be permitted to be kept in service. Batteries must be disconnected. Auxiliary batteries not connected to engine starting system may be left connected. External chargers or batteries are recommended for demonstration purposes. No battery charging is permitted inside the building. Combustible/flammable materials must not be stored beneath display vehicles. Fueling or de-fueling of vehicles is prohibited. Vehicles shall not be moved during exhibit hours. 36" of clear access or aisles must be maintained around the vehicle. Vehicles must be a minimum of 20 feet from exit of door or exit pathway. No leaks underneath vehicles. All operational drying equipment must have ducting that extends at least 6 1/2 feet above floor level.

**GENERAL INFORMATION**

Name of Exhibiting Company: \_\_\_\_\_

Contact Name: \_\_\_\_\_

Telephone Number: \_\_\_\_\_

Email Address: \_\_\_\_\_

Name of EAC/I&D Company: \_\_\_\_\_

Contact: \_\_\_\_\_

Cell Phone: \_\_\_\_\_

Name of Supervisor On-Site: \_\_\_\_\_

Cell Phone: \_\_\_\_\_

**VEHICLE INFORMATION**

Live or Dead Vehicle: \_\_\_\_\_

Type of Vehicle: \_\_\_\_\_

Location of Booth: \_\_\_\_\_

Please email complete Booth Vehicle Fire Marshal Permit Form before September 7, 2022 and send to [exhibit@printingunited.com](mailto:exhibit@printingunited.com).